





## **RECOMMENDED STRIPPING LENGTH**

## NOTES:

- 1.COUPLING RING, O-RINGS, CONTACTS AND SET SCREWS SHIPPED ASSEMBLED
- 2.CONTACTS ACCEPT 12, 14, AND 16 AWG WIRES
- 3.SET SCREW NEED TO BE BACKED OUT WITH ALLEN WRENCH PRIOR TO INSERTING WIRE CONDUCTORS
- 4.STRIP CABLE JACKET 3/4" MAX. STRIP WIRE INSULATION ABOUT 7/16"
- 5.INSERT STRIPPED CONDUCTOR INTO THE CONTACT OPENING, SET SCREW SHOULD BE TIGHTENED WITH THE ALLEN WRENCH AS NEEDED TO RETAIN CONDUCTOR
- **6.ALL DIMENSIONS ARE REFERENCE**

	Α	CS		10-02-24	DRAWING CREATED PER DOR 24-E284PK
	REV.	INI	Γ.	DATE	DESCRIPTION
	CHECKED BY:				PART NUMBER:  LAB - 0052
_	APPROVED BY:				CORSAII
	FILE:		SIZE:	1 OF 1	601 E. WILDWOOD VILLA PARK, IL 60181

**Rohs Compliant**